

The development of a dual-use low-cost CsI(Tl)-SiPM detector for radiation monitoring by authorities and members of the public

Steven James Bell¹, Craig Duff², Sotiris Ioannidis¹, Toby Izod², Martin Kelly¹, Louise McNamara², Peter Rhodes², Adam Tuff²

¹ National Physical Laboratory (Teddington, UK)

² Kromek (Sedgefield, UK)

steven.bell@npl.co.uk

peter.rhodes@kromek.com

Contents

- EMPIR Preparedness
- D3S
- D3M
- Dosimetry testing
- Next steps

EMPIR Preparedness

- Metrology for mobile detection of ionising radiation following a nuclear or radiological incident
- 3-year pan-European research project funded by EURAMET
- Collaboration of NMIs, monitoring agencies and industry
- Four technical work packages;
 - Drone mounted detector systems
 - Transportable air monitoring equipment (see poster)
 - **Citizen radiation monitoring**
 - Passive dosimetry for environmental monitoring
- Stefan Neumaier to present more details later...



Kromek D3S


- Dual gamma and neutron detector for homeland security
- Designed to be worn by government employees (police, fire, postal etc) for real-time radiation mapping of urban environment



Specifications:

Gamma detector :	CsI(Tl)-SiPM, 2" x 1" x 1/2"
Energy resolution:	7% (at 662 keV)
Energy range:	30 to 3,000 keV
Sensitivity:	500 cps/ μ Sv/h
Dose rate limit:	15 μ Sv/h (at 662 keV)
Connectivity:	Micro USB, Bluetooth®
Neutron detector:	LiF:ZnS-SiPM, 32 mm x 100 mm
Count rate limit:	5,000 cps
Size:	132 x 80 x 23.5 mm ³
Weight:	237 g
Battery life:	12 h

Kromek D3S



Radiological “heat” map of urban area produced by centralised database collecting data from multiple D3S units (DARPA trial, Washington DC)

Kromek D3M

- Modified version of D3S
- Photodiode used for high dose-rate measurement
- Other improvements:
 - IP65 rating
 - Improved battery life (24 hours)
 - Indoor tracking for GPS denied areas
 - Local display and alert (OLED Screen)
 - Vibrational and Sounder alarm
 - Internal storage (8GB MicroSD card)
 - Improved Linearity and stability for reduced false alarm rates
 - Low Energy Bluetooth (BLE)
- Preliminary dosimetric measurements made at NPL
- D3M will be produced for purchase and use by members of the public



Preliminary measurements – Experimental set-up


Range and accuracy:

- Each device was exposed to nine sources in turn – one Am-241, four each of Cs-137 and Co-60 at a range of distances
- For Cs-137, dose rates of $<0.5 \mu\text{Sv/hr}$ to $>1 \text{ Sv/hr}$ were possible

Rotational dependence:

- One device was exposed to a high-rate and a low-rate dose field for each source, and rotated 360° in 16 increments
- Both yaw and pitch was tested
- An electric turntable was used to facilitate the measurements

For all tests, the gamma spectrum, scintillator dose, and high-dose sensor reading, were recorded.






D3M

Electric
turntable

Preliminary measurements – Dose range and accuracy

Plotted are the responses for Cs-137 (blue: scintillator dose reading, orange: high-dose sensor count rate)

The scintillator dose rate was accurate at low dose rates for both Cs-137 and Co-60, staying within 10% up to 50 $\mu\text{Sv/hr}$




Preliminary measurements – Deadtime

The theoretical dead time model used for the scintillator dose rate calculation was found to be inaccurate beyond 50 Sv/hr

Modification of the deadtime extended the accurate ($\pm 10\%$) dose rate range up to 200 Sv/hr for Cs-137 and Co-60

200 Sv/hr proposed as crossover point from scintillator to high dose-rate sensor.




Preliminary measurements – High dose-rate sensor

High dose-rate sensor responsive beyond 1 Sv/hr


By applying a non-paralysable deadtime model, a deadtime of 8 μ s was determined

Deadtime model accurate to approx. $\pm 20\%$ at ~ 1.1 Sv/hr

D3M #1



D3M #3




Preliminary measurements – Angular response

Device exposed to low and high dose rates from three radionuclides:


- Am-241: 16 $\mu\text{Sv/hr}$ and 620 $\mu\text{Sv/hr}$
- Cs-137: 1.2 $\mu\text{Sv/hr}$ and 2.3 mSv/hr
- Co-60: 1.8 $\mu\text{Sv/hr}$ and 1.0 mSv/hr

The scintillator dose rate in the first and third plots were calculated from spectra which were saturated in the high dose-rate field


Low dose-rate response of high dose-rate sensor not plotted as count rate too low




Am-241 High Dose Rate Pitch Response



Cs-137 Low Dose-Rate Pitch



Co-60 High Dose Rate Yaw Response



— Spectrum Dose Rate (from scintillator) / $\mu\text{Sv/hr}$
— High-Dose Sensor Count Rate / Hz

Next steps

- A website will be trialled for the sharing of radiation measurements by members of the public. This will be developed with support from EURDEP, the European Radiological Data Exchange Platform [1].
- NPL and PTB will continue to metrologically validate the new instrument. This will include measuring the spectral response in the range 60 to 1,250 keV using X-ray and gamma-ray irradiation facilities, investigating the unit-to-unit variability.
- An extended site trial will be performed with comparisons made to passive or existing dose monitoring infrastructure.

Thank you for listening!

steven.bell@npl.co.uk

peter.rhodes@kromek.com



Department for
Business, Energy
& Industrial Strategy

FUNDED BY BEIS



The National Physical Laboratory is operated by NPL Management Ltd, a wholly-owned company of the Department for Business, Energy and Industrial Strategy (BEIS).